

AENOR

Keymark Certificate Solar thermal energy



078/000133

AENOR certifies that the organization

BDR THERMEA GROUP B.V

registered office MERCHANTSTRAAT, 55 7300 AA APELDOORN (Holanda - Países Bajos)

supplies Solar collectors

in compliance with UNE-EN 12975-1:2006 (EN 12975-1:2006)

Trade Mark BAXI SOL 250
Technical information Specified in Annexes to the Certificate

Production site CL MANGANÉS, 2 08755 CASTELLBISBAL (Barcelona - España)


Certification scheme In order to grant this Certificate, AENOR has tested the product and has verified the quality system implemented for its manufacture. AENOR performs these tasks periodically while the Certificate has not been cancelled, in accordance with Specific Rules RP 078.01.

This certificate supersedes 078/000133, dated 2017-07-24

First issued on 2012-07-24
Modified on 2017-10-10
Validity date 2022-07-24

Rafael GARCÍA MEIRO
Chief Executive Officer



Annex to Solar Keymark Certificate - Summary of EN ISO 9806:2013 Test Results						Licence Number		078/000133							
						Date issued		2017-10-10							
						Issued by									
Licence holder		BDR THERMEA GROUP B.V.				Country		NETHERLANDS							
Brand (optional)		Abrand				Web		http://www.bdrthermea.com							
Street, Number		MARCHANSTRAAT 55				E-mail		oleguer.fuertes@baxi.es							
Postcode, City		7300 AA, APPELDOORN				Tel		+34 902 89 80 00							
Collector Type						Flat plate collector, glazed									
Collector name					Gross area (A _G) m ²	Gross length mm	Gross width mm	Gross height mm	Power output per collector G _b = 850 W/m ² ; G _d = 150 W/m ² θ _m - θ _a						
									0 K W	10 K W	30 K W	50 K W	70 K W	90 K W	
BAXI SOL 250					2,51	2.187	1.147	87	1.925	1.838	1.639	1.406	1.139	837	
Power output per m ² gross area									767	732	653	560	454	333	
Performance parameters test method					Steady state - indoor										
Performance parameters (related to AG)					η _{0,hem}	a ₁	a ₂								
Units					-	W/(m ² K)	W/(m ² K ²)								
Test results					0,767	3,287	0,017								
Incidence angle modifier test method					Quasi dynamic - outdoor										
Bi-directional incidence angle modifiers					No										
Incidence angle modifier					Angle	10°	20°	30°	40°	50°	60°	70°	80°	90°	
Transversal					K _{θT, coll}	1,00	0,99	0,97	0,95	0,91	0,83	0,67	-	0,00	
Longitudinal					K _{θL, coll}	1,00	0,99	0,97	0,95	0,91	0,83	0,67	-	0,00	
Heat transfer medium for testing					Water										
Flow rate for testing (per gross area, A _G)					dm/dt		0,019	kg/(sm ²)							
Maximum temperature difference for thermal performance calculations					(θ _m -θ _a) _{max}		90	K							
Standard stagnation temperature (G = 1000 W/m ² ; θ _a = 30 °C)					θ _{stg}		200	°C							
Effective thermal capacity, incl. fluid (per gross area, A _G)					C/m ²		6,38	kJ/(Km ²)							
Maximum operating temperature					θ _{max, op}		n.n.	°C							
Maximum operating pressure					p _{max, op}		1000	kPa							
Testing laboratory					TÜV Rheinland Energy GmbH				http://www.tuv.com/st						
Test report(s)					21240494.002_SOL250H_R 21217926_EN_P_SOL250V				Dated		26/09/2017 04/06/2012				
Comments of testing laboratory					Datashet version: 5.01, 2016-03-01										
*The initial thermal performance testing was not performed according to ISO 9806:2013, but EN 12975-2:2006. The steady state test evaluation was recalculated with gross area. The former values related to 2.372 m ² aperture area had been: eta0a=0.812; a1a=3.478; a2a=0.018.					 TÜVRheinland® Precisely Right.										
AENOR INTERNACIONAL, S.A.U. - Génova, 6. - 28004 - Madrid, España - Tel. 91 432 60 00 - www.aenor.com															
Product certification body accredited by ENAC, number 01/C-PR002.078															



Annex to Solar Keymark Certificate Supplementary Information	Licence Number	078/000133
	Issued	2017-10-10

Annual collector output in kWh/collector at mean fluid temperature ϑ_m , based on EN ISO 9806:2013 test results

Collector name	Standard Locations ϑ_m	Athens			Davos			Stockholm			Würzburg		
		25°C	50°C	75°C	25°C	50°C	75°C	25°C	50°C	75°C	25°C	50°C	75°C
BAXI SOL 250		2.986	2.149	1.394	2.292	1.587	983	1.682	1.108	665	1.823	1.192	703
Annual output per m ² gross area		1.190	856	555	913	632	392	670	442	265	726	475	280
Fixed or tracking collector		Fixed (slope = latitude - 15°; rounded to nearest 5°)											
Annual irradiation on collector plane		1765 kWh/m ²			1714 kWh/m ²			1166 kWh/m ²			1244 kWh/m ²		
Mean annual ambient air temperature		18,5°C			3,2°C			7,5°C			9,0°C		
Collector orientation or tracking mode		South, 25°			South, 30°			South, 45°			South, 35°		

The collector is operated at constant temperature ϑ_m (mean of in- and outlet temperatures). The calculation of the annual collector performance is performed with the official Solar Keymark spreadsheet tool Scenocalc Ver. 5.01 (March 2016). A detailed description of the calculations is available at www.solarkeymark.org/scenocalc

Additional Information

Collector heat transfer medium	Water-Glycole
Hybrid Thermal and Photo Voltaic collector	No
The collector is deemed to be suitable for roof integration	Yes
The collector was tested successfully according to EN ISO 9806:2013 under the following conditions:	
Climate class (A, B or C)	A --
Maximum tested positive load	5400 Pa
Maximum tested negative load	3000 Pa
Hail resistance using ice balls (diameter)	35 mm

Energy Labelling Information

	Reference Area, A_{sol} (m ²)	Data required for CDR (EU) No 811/2013 - Reference Area A_{sol}	
BAXI SOL 250	2,51	Collector efficiency (η_{col})	61 %
		<i>Remark: Collector efficiency (η_{col}) is defined in CDR (EU) No 811/2013 as collector efficiency of the solar collector at a temperature difference between the solar collector and the surrounding air of 40 K and a global solar irradiance of 1000 W/m², expressed in % and rounded to the nearest integer. Deviating from the regulation η_{col} is based on reference area (A_{sol}) which is aperture area for values according to EN 12975-2 or gross area for ISO 9806:2013.</i>	
		Data required for CDR (EU) No 812/2013 - Reference Area A_{sol}	
		Zero-loss efficiency (η_0)	0,767 --
		First-order coefficient (a_1)	3,29 W/(m ² K)
		Second-order coefficient (a_2)	0,017 W/(m ² K ²)
		Incidence angle modifier IAM (50°)	0,91 --
		<i>Remark: The data given in this section are related to collector reference area (A_{sol}) which is aperture area for values according to EN 12975-2 or gross area for ISO 9806. Consistent data sets for either aperture or gross area can be used in calculations like in the regulation 811 and 812 and simulation programs.</i>	