

**EC type examination certificate****EG-Baumusterprüfbescheinigung****CE-0085CP0089**Product Identification No.  
Produkt-Identnummer

<b>Field of Application</b> <i>Anwendungsbereich</i>	EC Gas Appliances Directive (2009/142/EC) <i>EG-Gasgeräte-Richtlinie (2009/142/EG)</i>
<b>Distributor</b> <i>Vertreiber</i>	BAXI Calefacción, S.L.U. Salvador Espriu, 9, E-08908 L'Hospitalet de Llobregat-Barcelona
<b>Product Category</b> <i>Produktart</i>	Boilers with flue systems: Condensing water heater (3202)
<b>Product Description</b> <i>Produktbezeichnung</i>	floor standing condensing water heater with automatic burner control and gas/combustion-air ratio control
<b>Model</b> <i>Modell</i>	POWER HT PLUS...
<b>Countries of Destination</b> <i>Bestimmungsländer</i>	AL, AT, BE, BG, BY, CH, CY, CZ, DE, DK, EE, ES, FI, FR, GB, GR, HR, HU, IE, IS, IT, LT, LU, LV, MK, MT, NL, NO, PL, PT, RO, RU, SE, SI, SK, TR, UA
<b>Test Reports</b> <i>Prüfberichte</i>	type testing: 13/211/3204/139 from 30.04.2014 (EBI)
<b>Test Basis</b> <i>Prüfgrundlagen</i>	EU/2009/142/EG (30.11.2009) DIN EN 15502-1 (01.10.2012) DIN EN 15502-2/1 (draft 01.01.2012)

**File Number**  
*Aktenzeichen* 13-0733-GEE

20.05.2014 Kö C-1/2

Date, Issued by, Sheet, Head of Certification Body  
*Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle*

DVGW CERT GmbH is an accredited body by DAkkS according to EN 45011:1998 and notified by the government of the Federal Republic of Germany for certification of gas appliances under EC Directive 2009/142/EC.

DVGW CERT GmbH ist von der DAkkS nach DIN EN 45011:1998 akkreditierte und von der Deutschen Bundesregierung benannte Stelle für die Zertifizierung von Gasgeräten gemäß EG-Richtlinie 2009/142/EG.

Deutsche  
Akkreditierungsstelle  
D-ZE-16028-01-01DVGW CERT GmbH  
ZertifizierungsstelleJosef-Wirmer-Str. 1-3  
53123 BonnTel. +49 228 91 88 - 888  
Fax +49 228 91 88 - 993www.dvgw-cert.com  
info@dvgw-cert.com



Appliance Categories <i>Gerätekategorien</i>	Supply Pressures <i>Versorgungsdrücke</i>	Countries of Destination <i>Bestimmungsländer</i>	Remarks <i>Bemerkungen</i>
I2E(R)	20/25 mbar	BE	
I3P	30 mbar	IS, MT	
I3P	37 mbar	BE	
II2E Lw3P	20, 37 mbar	PL	
II2E3P	20, 37 mbar	LU	
II2E3P	20, 50 mbar	DE	
II2Esi3P	20/25, 37 mbar	FR	
II2H3P	20, 30 mbar	DK, EE, FI, LT, LV, NO, RO, SE, SI	
II2H3P	20, 37 mbar	CH, CZ, ES, GB, GR, HR, IE, PT, SK, TR	
II2H3P	20, 50 mbar	AT	
II2HM3P	20, 37 mbar	IT	
II2HS3P	25, 30 mbar	HU	
II2L3P	25, 37 mbar	NL	

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
POWER HT PLUS 50	nominal heat output: 5,0...45,0 kW heat input (Hi): 5,1...46,3 kW	
POWER HT PLUS 70	nominal heat output: 7,2...65,0 kW heat input (Hi): 7,4...66,9 kW	
POWER HT PLUS 90	nominal heat output: 9,4...85,0 kW heat input (Hi): 9,7...87,4 kW	
POWER HT PLUS 110	nominal heat output: 11,4...102,0 kW heat input (Hi): 11 kW	

#### Hints of Utilization /Remarks

##### Verwendungshinweise / Bemerkungen

Flue types B23, B23P, C13, C33, C43, C53, C63 und C83: according to installation manual no. 7609489 (ES) and 7609491 (PT)

Additionally tested appliance categories, supply pressures and countries of destination:

AL, MK: II2H3P (20, 30 mbar)

MT: II2H3P (20, 37 mbar)

BY, RU, UA: II2H3P (20, 30 und 50 mbar)

BG: II2H3P (20, 37 und 50 mbar)

In Albania, Belarus, Macedonia, in the Russian Federation and in the Ukraine the CE-marking will be accepted as conformaty approval if the Gas Appliance Directive (2009/142/EC) is transferred into national law by Albania, Belarus, Macedonia, the Russian Federation respectively by the Ukraine.

# EC type examination certificate

## EG-Baumusterprüfbescheinigung

**CE-0085CP0089**Product Identification No.  
Produkt-Identnummer

<b>Field of Application</b> <i>Anwendungsbereich</i>	EC Efficiency Directive (92/42/EEC) <i>EG-Wirkungsgradrichtlinie (92/42/EWG)</i>
<b>Distributor</b> <i>Vertreiber</i>	BAXI Calefacción, S.L.U. Salvador Espriu, 9, E-08908 L'Hospitalet de Llobregat-Barcelona
<b>Product Category</b> <i>Produktart</i>	Boilers with flue systems: Condensing water heater (3202)
<b>Product Description</b> <i>Produktbezeichnung</i>	floor standing condensing water heater with automatic burner control and gas/combustion-air ratio control
<b>Model</b> <i>Modell</i>	POWER HT PLUS...
<b>Type of Boiler</b> <i>Heizkesseltyp</i>	condensing boiler
<b>Test Reports</b> <i>Prüfberichte</i>	type testing: 13/211/3204/139 from 30.04.2014 (EBI)
<b>Test Basis</b> <i>Prüfgrundlagen</i>	EU/92/42 (21.05.1992)
<b>File Number</b> <i>Aktenzeichen</i>	13-0733-GWE

20.05.2014 K6 C-1/2

Date, Issued by, Sheet, Head of Certification Body  
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH - recognized by the German Institute for Building Technology (DIBt) and notified at the European Commission as certification body for the EC Boiler Efficiency Directive

DVGW CERT GmbH - vom Deutschen Institut für Bautechnik (DIBt) nach dem Bauproduktengesetz anerkannte und bei der Europäischen Kommission benannte Zertifizierungsstelle für die EG-Heizkessel-Wirkungsgradrichtlinie

**DIBt**  
ZP 42DVGW CERT GmbH  
ZertifizierungsstelleJosef-Wirmer-Str. 1-3  
53123 BonnTel. +49 228 91 88 - 888  
Fax +49 228 91 88 - 993www.dvgw-cert.com  
info@dvgw-cert.com



Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Energy Labelling <i>Energieeffizienzkennzeichnung</i>
POWER HT PLUS 50	nominal heat output: 5,0...45,0 kW heat input (Hi): 5,1...46,3 kW	****
POWER HT PLUS 70	nominal heat output: 7,2...65,0 kW heat input (Hi): 7,4...66,9 kW	****
POWER HT PLUS 90	nominal heat output: 9,4...85,0 kW heat input (Hi): 9,7...87,4 kW	****
POWER HT PLUS 110	nominal heat output: 11,4...102,0 kW heat input (Hi): 11 kW	****

#### Hints of Utilization / Remarks

##### *Verwendungshinweise / Bemerkungen*

The energy labelling can be used according to the actual regulations of the country of destination for the individual types.  
The above listed model was certified under the Product-Identnumber CE-0085CP0089 according to the Gas Appliance Directive (2009/142/EC).